West Virginia's Public Record on Underground Storage Tanks

General Information: Posted October 24, 2014

Total Number of UST Facilities: 1544
Total Number of Underground Storage Tanks (USTs): 4155

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 742

Inspection Period Dates: 10/1/2013 to 9/30/2014

Percent Compliance (Combined Measure) 76%

Summary Information for Releases

Number of Confirmed UST Releases 73

Release Reporting Period Dates 10/1/2013 to 9/30/2014

Note: Tank, facility and on-site inspection information is based on undergrounds storage tanks regulated under Chapter 22 Article 17 of the West Virginia Code. On-site inspections measure compliance with release detection and release prevention measures of the significant operational compliance requirements described in EPA's September 30, 2003 Memorandum. Sources of release may total more than the number of confirmed releases due to some sites having multiple sources of releases. Specific information on underground storage tank release prevention is available through WVDEP's Office of Environmental Enforcement/UST Unit at 304-926-0470. Specific information on releases from underground storage tanks is available through WVDEP's Office of Environmental Remediation at 304-238-1220. The total number of USTs reflects tanks that are Temporarily out of service and currently in use, but does not reflect the number of abandoned USTS (410).

Summary Information For Release Sources and Causes

Source				Cause														
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown			
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%		
Tank	42	50.0	5	11.9	9	21.4	1	2.4	17	40.5	1	20.0			9	21.4		
Piping	24	28.6					9	37.5	11	45.8					4	16.7		
Dispenser	7	8.3	4	57.1			3	42.9										
STP	1	1.2					1	100.0										
Delivery Problem	2	2.4	1	50.0	1	100.0		0.0										
Other	0	0.0																
Unknown	8	9.5													8	100.0		
Totals	84	100.0	10	11.9	10	11.9	14	16.7	28	33.3	0	0.0	0	0.0	21	25.0		